

PRODUCT-DETAILS

CM-PSS.41S

CM-PSS.41S Three-phase monitoring relay 2c/o, 0,0.1-30s, L1-L2-L3=3x400VAC



General Information Extended Product Type CM-PSS.41S Product ID 1SVR730784R3300 EAN 4016779851824 Catalog Description CM-PSS.41S Three-phase monitoring relay 2c/o, 0,0.1-30s, L1-L2-L3=3x400VAC The CM-PSS.41S relay is from the CM three-phase monitors range. This relay operates with a rated control supply voltage / three-phase measuring voltage of 400 V AC and has a 2 c/o output with contacts rated at 250 V / 4 A. The CM-PSS.41S monitors the phase parameters over/undervoltage and phase failure. Phase sequence monitoring Long Description as well as an ON or OFF tripping delay are selectable. The tripping delay is adjustable over a range of instantaneous to 30 s (0, 0.1-30 s). A sealable transparent cover for protection against unauthorized changes is available as accessory. The device offers screw connection technology with double-chamber cage connection terminals.

Ordering	
EAN	4016779851824
Minimum Order Quantity	1 piece
Customs Tariff Number	85364900

© 2024 ABB. All rights reserved.

2024/04/12

Subject to change without notice

Popular Downloads	
Data Sheet, Technical Information	2CDC112178D0201
Instructions and Manuals	1SVC730730M1000 1SVC730730M0000
CAD Dimensional Drawing	2CDC001079B0201

Dimensions

Product Net Width	22.5 mm
Product Net Height	85.6 mm
Product Net Depth / Length	103.7 mm
Product Net Weight	0.132 kg

Technical	
Function	Phase failure detection
	Phase sequence monitoring Over- and undervoltage monitoring
Measuring Range	(L-L) 360 440 V AC
Time Range	200 ms start-up delay 0 s or 0.1 30 s tripping delay (ON or OFF)
Rated Control Supply Voltage (U _S)	(L-L) 400 V AC
Rated Frequency (f)	Supply Circuit 50/60 Hz
Output	2 c/o (SPDT) contacts
Terminal Type	Screw Terminals
Rated Operational Current AC-12 (I _e)	(230 V) 4 A
Rated Operational Current AC-15 (I _e)	(230 V) 3 A
Rated Operational Current DC-12 (I _e)	(24 V) 4 A
Rated Operational Current DC-13 (I _e)	(24 V) 2 A
Minimum Switching Capacity	24 V 10 mA
Rated Impulse Withstand Voltage (U _{imp})	Input Circuit 6 kV Output Circuit 4 kV
Rated Insulation Voltage (U _i)	Input Circuit / Output Circuit 600 V Output Circuit 1 / Output Circuit 2 300 V
Degree of Protection	Housing IP50 Terminals IP20
Overvoltage Category	
Pollution Degree	3
Short-Circuit Protective Devices	Output Circuit NC - F Type Fuses 6 A Output Circuit NO - F Type Fuses 10 A
Electrical Durability	AC-12 100000 cycle
Mechanical Durability	30000000 cycle
Connecting Capacity	Flexible with Ferrule 1x 0.5 2.5 mm ² Flexible with Ferrule 2x 0.5 1.5 mm ² Flexible with Insulated Ferrule 1x 0.5 2.5 mm ² Flexible with Insulated Ferrule 2x 0.5 1.5 mm ² Flexible 1x 0.5 2.5 mm ² Flexible 2x 0.5 1.5 mm ²

Subject to change without notice

Rigid 1x 0.5 4 mm ²
Rigid 2x 0.5 2.5 mm²
0.6 0.8 N·m
8 mm
0.8 × 4
4.5
Pozidriv 1
16
TH35-15 (35 x 15 mm Mounting Rail) acc. to IEC 60715
TH35-7.5 (35 x 7.5 mm Mounting Rail) acc. to IEC 60715
CAN/CSA C22.2 No.14
IEC/EN 63000
IEC/EN 60255-27
IEC/EN 61000-6-2
IEC/EN 61000-6-3
UL 508

Technical UL/CSA	
Maximum Operating Voltage UL/CSA	Output Circuit 300 V AC
Contact Rating UL/CSA	B300
Connecting Capacity UL/CSA	Flexible 1x 18-14 AWG Flexible 2x 18-16 AWG Rigid 1x 20-12 AWG Rigid 2x 20-14 AWG
Tightening Torque UL/CSA	7.08 in lb
Pilot Duty UL/CSA	B300
Flammability According to UL94	V-C
Ambient Air Temperature	Operation -25 +60 °C Storage -40 +85 °C
Maximum Operating	Without Derating 2000 m
Maximum Operating Altitude Permissible	, ,
	, ,
Altitude Permissible	
Altitude Permissible Material Compliance Conflict Minerals Reporting Template (CMRT)	Without Derating 2000 m
Altitude Permissible Material Compliance Conflict Minerals Reporting Template	Without Derating 2000 m 9AKK108467A5658 1SVD981001-4501
Altitude Permissible Material Compliance Conflict Minerals Reporting Template (CMRT) REACH Declaration	Without Derating 2000 m 9AKK108467A5658

Circular Value

End of Life Instructions

Certificates and Declarations

© 2024 ABB. All rights reserved.

Subject to change without notice

1SAC200290H0001

CQC Certificate	CQC2009010303326655
cULus Certificate	cULus508_20120829-E140448
Declaration of Conformity - CCC	2020980303000197
Declaration of Conformity - CE	15VD981014-00
Declaration of Conformity - UKCA	1SVD981014-10
DNV GL Certificate	DNV_GL_TAA000017D

Container Information

Package Level 1 Units	box 1 piece
Package Level 1 Width	97 mm
Package Level 1 Depth / Length	30 mm
Package Level 1 Height	109 mm
Package Level 1 Gross Weight	0.157 kg
Package Level 1 EAN	4016779851824

Classifications	
Object Classification Code	В
ETIM 7	EC001441 - Phase monitoring relay
ETIM 8	EC001441 - Phase monitoring relay
ETIM 9	EC001441 - Phase monitoring relay
eClass	V11.0 : 27371803
UNSPSC	39122332
E-Number (Finland)	2712290
E-Number (Sweden)	3860582

Categories

Low Voltage Products and Systems \rightarrow Control Products \rightarrow Electronic Relays and Controls \rightarrow Three Phase Monitors

