ESB20-20N-14 1/5



PRODUCT-DETAILS

ESB20-20N-14

ESB20-20N-14 Installation Contactor (NO) 20 A - 2 NO - 0 NC - 12 V - Control Circuit DC



Extended Product Type	ESB20-20N-14
Product ID	1SBE121111R1420
EAN	3471523007567
Catalog Description	ESB20-20N-14 Installation Contactor (NO) 20 A - 2 NO - 0 NC - 12 V - Control Circuit DC
Long Description	The ESB20N installation contactors are used to control single loads up to 20 A and can be operated by AC or DC.
	These contactors are made for use in household applications as well as in industrial environments. The following benefits are provided:
	Hum-free operation, low power consumption and integrated overvoltage protection. Various contact combinations and accessories are available.

Ordering	
Package Level 1 EAN	3471523004672
Minimum Order Quantity	1 piece
Customs Tariff Number	<u>85365080</u>

Popular Downloads

ESB20-20N-14 2/5

Data Sheet, Technical Information	2CDC103051C0201	
Instructions and Manuals	2CDC103043M6801	
CAD Dimensional	2CDC001079B0201	
Drawing		
Dimension Diagram	1SBB505186D3001	
Dimensions		
Product Net Width	18 mm	
Product Net Height	85 mm	
Product Net Depth / Length	65 mm	
Product Net Weight	0.14 kg	
Technical		
Rated Operational Voltage	Main Circuit 220 V DC Main Circuit 250 V AC	
Rated Control Circuit Voltage (U _c)	12 V	
Rated Frequency (f)	Control Circuit DC Control Circuit 50 Hz Control Circuit 60 Hz Control Circuit 400 Hz Main Circuit DC Main Circuit 50 Hz	
Rated Operational Current AC-1 (I _e)	Main Circuit 60 Hz (NO) 20 A	
Rated Operational Current AC-3 (I _e)	(230 V) Single Phase, NO 9 A	
Rated Operational Power AC-1 (P _e)	(230 V) Single Phase, NO 4.6 kW	
Rated Operational Power AC-3 (P _e)	(230 V) Single Phase, NO 1.3 kW	
Rated Operational Current AC-7a (I _e)	(NO) 20 A	
Rated Operational Power AC-7a (P_e)	(230 V) Single Phase, NO 4.6 kW	
Rated Operational Current AC-7b (I_e)	(230 V) Single Phase, NO 9 A	
Rated Operational Power AC-7b (P _e)	(230 V) Single Phase, NO 1.3 kW	
Recommended Screw Driver	Control Circuit Pozidriv 1 Main Circuit Pozidriv 1	
Rated Impulse Withstand Voltage (U _{imp})	6 kV	
Rated Insulation Voltage (U _i)	400 V	
Connecting Capacity Main Circuit Connecting Capacity	Flexible with Ferrule 1x 1 6 mm² Flexible with Ferrule 2x 1 2.5 mm² Flexible with Insulated Ferrule 1x 1 6 mm² Flexible with Insulated Ferrule 2x 1 1.5 mm² Flexible 1x 1 6 mm² Flexible 2x 1 4 mm² Rigid 1x 1 10 mm² Rigid 2x 1 4 mm² Flexible with Ferrule 1x 1 2.5 mm²	
Control Circuit	Flexible with Ferrule 2x 0.75 1.5 mm² Flexible with Insulated Ferrule 1x 1 2.5 mm² Flexible with Insulated Ferrule 2x 0.75 1 mm² Flexible 1x 1 2.5 mm² Flexible 2x 1 1.5 mm² Rigid 1x 0.5 4 mm²	
	0004104110	

ESB20-20N-14 3/5

	Rigid 2x 0.75 2.5 mm²
Tightening Torque	Control Circuit 0.9 N·m Main Circuit 1.2 N·m
Wire Stripping Length	Control Circuit 7 mm Main Circuit 10 mm
Degree of Protection	IP20
Electrical Durability	AC-1 (NO) 150000 cycle AC-3 (NO) 150000 cycle AC-7a (NO) 150000 cycle AC-7b (NO) 150000 cycle
Mechanical Durability	1000000 cycle
Number of Poles	2
Number of Auxiliary Contacts NC	0
Number of Auxiliary Contacts NO	0
Number of Main Contacts NC	0
Number of Main Contacts NO	2
Width in Number of Modular Spacings	1
Pollution Degree	3 IFC/FN 60047.1
Standards	IEC/EN 60947-1 IEC/EN 60947-4-1 UL 60947-4-1 UL 60947-4-1 IEC/EN 61095
	IEC/EN 01095
Technical UL/CSA	
Maximum Operating Voltage UL/CSA	Main Circuit 240 V AC
Horsepower Rating UL/CSA	(220 240 V AC) Single Phase, NO 1 Hp
Connecting Capacity Main Circuit UL/CSA	Solid 14-8 AWG Stranded 14-8 AWG
Connecting Capacity Control Circuit UL/CSA	Solid 16-10 AWG Stranded 16-10 AWG
Tightening Torque UL/CSA	Control Circuit 8 in·lb Main Circuit 11 in·lb
Environmental	
Ambient Air Temperature	Operation -25 +55 °C
Maximum Operating	Storage -40 +80 °C 2000 m
Altitude Permissible Resistance to Shock acc.	11 ms Pulse 15g
to IEC 60068-2-27 RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019
Material Compliance	
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
REACH Declaration	2CMT2021-006202
RoHS Information	2CMT2021-006277
RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019
Toxic Substances Control Act - TSCA	2CMT2023-006525
WEEE B2C / B2B	Business To Consumer

ABS Certificate	1SAA920000-010
CB Certificate	1SAA920007-200 ⁻
CQC Certificate	CQC2018010304057353 CQC2018010304057344
Declaration of Conformity - CCC	2020980304001370 202098030400137
Declaration of Conformity - CE	1SAD101100-330
Declaration of Conformity - UKCA	1SAD201100-330 ⁻
DNV Certificate	1SAA920000-0306
EAC Certificate	1SAA920003-270 ⁻
NF Certificate	1SAA920002-120 ⁻
RMRS Certificate	1SAA920000-0705
UL Certificate	E191658-1996030

Container Information	
Package Level 1 Units	1 piece
Package Level 1 Width	88 mm
Package Level 1 Height	71 mm
Package Level 1 Depth / Length	20 mm
Package Level 1 Gross Weight	0.14 kg
Package Level 1 EAN	3471523004672

Classifications	
Object Classification Code	Q
ETIM 5	EC001653 - Installation contactor for distribution board
ETIM 6	EC001653 - Installation contactor for distribution board
ETIM 7	EC001653 - Installation contactor for distribution board
eClass	V11.0 : 27142308
UNSPSC	39121529
IDEA Granular Category Code (IGCC)	4759 >> Installation contactor for distribution board
ETIM 8	EC001653 - Installation contactor for distribution board

Accessories				
Identifier	Description	Туре	Quantity	Unit Of Measure
1SAE901901R1011	EH04-11N Auxiliary Contact - 0 NO - 0 NC - Auxiliary Circuit 50 Hz	EH04-11N	1	piece
1SAE901901M1011	EH04-11N Auxiliary Contact - 0 NO - 0 NC - Auxiliary Circuit 50 Hz	EH04-11N	1	piece
1SAE901901R1020	EH04-20N Auxiliary Contact - 0 NO - 0 NC - Auxiliary Circuit 50 Hz	EH04-20N	1	piece
1SAE901901M1020	EH04-20N Auxiliary Contact - 0 NO - 0 NC - Auxiliary Circuit 50 Hz	EH04-20N	1	piece

ESB20-20N-14 5/5

Categories

 $Low\ Voltage\ Products\ and\ Systems\ \rightarrow\ Control\ Products\ \rightarrow\ Contactors\ \rightarrow\ Installation\ Contactors$ $Low\ Voltage\ Products\ and\ Systems\ \rightarrow\ Modular\ DIN\ Rail\ Products\ \rightarrow\ Command\ and\ Signalling\ Devices\ \rightarrow\ Installation\ Contactors$

